



ITEM	DESCRIPTION	CATALOG NUMBERS AND SIZES	
		FOR 1-1/2" METER	FOR 2" METER
A	PLASTIC PITSETTER METER PIT	PMBHH-688-36-60-NL	PMBHH-788-36-60-NL
B	INLET AND OUTLET SIZES	1-1/2"	2"
C	FITTING GAP FOR METER	13"	15.25"
D	ANGLE BALL VALVE	(INCLUDED IN ITEM "A")	
E	ANGLE DUAL CHECK VALVE	(INCLUDED IN ITEM "A")	
F	INSULATING DISK (4" THICK)	CCID-36-4-2	
G	PIT COVER W/ERT BRACKET	MC-36-P-BR	

NOTES:

1. METER PIT AND YOKE NEED NOT BE A PRE-ASSEMBLED UNIT AS DEPICTED. THE ABOVE ITEMS SHALL BE AS MANUFACTURED BY THE FORD METER BOX COMPANY. FITTINGS OF EQUAL QUALITY WILL BE ACCEPTED BY THE LAKEWOOD TOWNSHIP MUNICIPAL UTILITIES AUTHORITY (LTMUA) AS DETERMINED BY THE LTMUA ENGINEER.
2. OWNER IS RESPONSIBLE TO VERIFY COMPATIBILITY AND ALL CATALOG NUMBERS PRIOR TO ORDERING MATERIAL.
3. OWNER IS RESPONSIBLE FOR ALL FITTINGS REQUIRED TO CONNECT SERVICE LINES TO LOWER FITTINGS.

REVISED 5-9-22	REVISED ITEM "C" DIMENSION FOR 2"
REVISED 4-5-18	GENERAL REVISIONS BY GTS CONSULTANTS
REVISED 10-8-03	CADD DRAWING BY GTS CONSULTANTS, INC.

DATE: JAN. 1991	LAKWOOD TOWNSHIP MUNICIPAL UTILITIES AUTHORITY	1-1/2" OR 2" METER PIT DETAIL	17
DRAWN: G.G. & J.T.R.			
SCALE: NONE			